Mucool Shielding Requirements

Experiment Mode Beam to Experiment in MTA Hall

> Base Primary Beam Energy (GeV): 1000.00 Base Primary Beam Intensity (protons/pulse): 2.00E+13

Primary Beam Energy (GeV): Primary Beam Intensity (protons/pulse): Accelerator Cycle Time (sec): Number of Trips per Hour:

Date:

7/13/2010 0.4 1.60E+13 60 15 Number of Protons per Hour:

Standard Cossairt category table, assuming 2E13 protons/pulse at E=1000 GeV, 57-sec cycle time

Accident dose limits from Fermilab Radiological Control Manual, January 1997 revision, tables 2-7A and 2-7B

Note: For categories 6 through 10, standard assumes one trip allowed per hour will give dose limit

	A. Beam on Magnet in Enclosure			Pipe in Enclosure	C. Beam or	C. Beam on Buried Pipe		
		Standard		Standard		Standard		
Dose D, per hour	Category	(e.f.d.)	Category	(e.f.d.)	Category	(e.f.d.)		
D < 1mrem	1A	22.0	1B	20.0	1C	24.0		
1 ≤ D ≤ 5 mrem	2A	19.8	2B	17.8	2C	21.8		
1 ≤ D ≤ 10 mrem	2SE-A	19.3	2SE-B	18.3	2SE-C	20.8		
10 ≤ D ≤ 100 mrem	3A	16.5	3B	15.5	3C	18.0		
100 ≤ D ≤ 500 mrem	4A	15.0	4B	13.0	4C	16.5		
500 ≤ D ≤ 1000 mrem	5A	14.0	5B	12.0	5C	15.5		
D < 1mrem	6A	17.3	6B	15.3	6C	18.3		
1 ≤ D ≤ 5 mrem	7A	15.2	7B	13.2	7C	16.2		
5 ≤ D ≤ 100 mrem	8A	11.7	8B	9.7	8C	12.7		
100 ≤ D ≤ 500 mrem	9A	10.2	9B	8.2	9C	11.2		
500 ≤ D ≤ 1000 mrem	10A	9.2	10B	7.2	10C	10.2		
D ≤ 250 mrem/trip	11A		11B		11C			

Scaled Thickness Requirements for this intensity, energy, and cycle time:

	· · · · · · · · · · · · · · · · · · ·			•				•		
	Cossairt	Standard	Scaled		Standard	Scaled		Standard	Scaled	
	Category	(e.f.d.)	Thickness	Category	(e.f.d.)	Thickness	Category	(e.f.d.)	Thickness	
D < 1mrem	1A	22.0	14.1	1B	20.0	12.1	1C	24.0	16.1	
1 ≤ D ≤ 5 mrem	2A	19.8	11.9	2B	17.8	9.9	2C	21.8	13.9	
1 ≤ D ≤ 10 mrem	2SE-A	19.3	11.4	2SE-B	18.3	10.4	2SE-C	20.8	12.9	
10 ≤ D ≤ 100 mrem	3A	16.5	8.6	3B	15.5	7.6	3C	18.0	10.1	
100 ≤ D ≤ 500 mrem	4A	15.0	7.1	4B	13.0	5.1	4C	16.5	8.6	
500 ≤ D ≤ 1000 mrem	5A	14.0	6.1	5B	12.0	4.1	5C	15.5	7.6	
D < 1mrem	6A	17.3	12.7	6B	15.3	10.7	6C	18.3	13.7	
1 ≤ D ≤ 5 mrem	7A	15.2	10.6	7B	13.2	8.6	7C	16.2	11.6	
5 ≤ D ≤ 100 mrem	8A	11.7	7.1	8B	9.7	5.1	8C	12.7	8.1	
100 ≤ D ≤ 500 mrem	9A	10.2	5.6	9B	8.2	3.6	9C	11.2	6.6	
500 ≤ D ≤ 1000 mrem	10A	9.2	4.6	10B	7.2	2.6	10C	10.2	5.6	

Note:

Categories 6 through 10 assume hourly trip rate is limited to value in "Number of Trips per Hour" cell above. and requirement is independent of cycle time.

A. Beam on Magnet in Enclosure

1. A new invented category, designated "2SE," is assigned for the dose interval less than 10 millirem per hour. Values defined are "2SE-A," "2SE-B," and "2SE-C."

B. Beam on Pipe in Enclosure

- 2. 1000 GeV shielding requirements are scaled downward from those for 100 mrem/hour (category 4) in the Cossairt table.
- 3. Apparatus has been added to handle Category values with either (a) a number followed by one character or (b) a number followed by four characters.

	Name/Date
Originated W. Higgins	14-Apr-10
Checked	

C. Beam on Buried Pipe